

# ARGONNE NATIONAL LABORATORY

## LIFE SAFETY / FIRE INSPECTION CHECKLIST

Date: \_\_\_\_\_ Inspection for Month: \_\_\_\_\_ Year: \_\_\_\_\_  
 Building: \_\_\_\_\_ Area/Wing: \_\_\_\_\_

**Fire Protection System**

**OK Not OK**

- Storage under sprinkler heads
- Pipes/Heads free of hanging mat'l
- Alarm panel Access
- Sprinkler/Detector heads
- Exits/Corridors not obstructed
- Fire-rated doors not blocked open
- Door in exit path operable
- Stairs clear and serviceable
- Fire extinguisher or signs visible
- Fire extinguishers not obstructed

**Electrical**

- Access to electrical panels

**Emergency Lighting**

**OK Not OK**

- Lighted Exit signs working
- Housekeeping**
- Areas orderly and free of debris
  - Exit doors/stairs free of obstructions

**Flammable/Combustible Liquids**

- Storage cabinets
- Storage rooms
- Lab/Shop use

**Compressed Gas Cylinders**

- Properly Secured
- Fuel/Oxidizers Separated

<b>Location</b>	<b>Description</b>	<b>MSR /Action</b>

Inspection By: \_\_\_\_\_  
 Cc: Building Manager  
 Division ESH Coordinator