

Reputable Manufacturer Unlisted Electrical Equipment Approval Form For use at Argonne National Laboratory

Division:	<input style="width: 95%;" type="text"/>	Manufacturer	<input style="width: 95%;" type="text"/>
Equipment Owner	<input style="width: 95%;" type="text"/>	Model Number	<input style="width: 95%;" type="text"/>
Equipment Name	<input style="width: 95%;" type="text"/>	Serial Number	<input style="width: 95%;" type="text"/>
Equipment Location	Building <input style="width: 20px;" type="text"/> Room <input style="width: 20px;" type="text"/>	Argonne Property Number	<input style="width: 95%;" type="text"/>

Label Number:

Multiple Single

Unlisted equipment that is determined to be safe to operate will have a tracking sticker attached for identification. Equipment that does not pass this evaluation will have a REJECTED sticker attached.

Use the following factors when evaluating equipment [NEC 110-3].

	Approve	Reject
1. The case is grounded through the power cord to the grounding pin on the plug.	<input type="checkbox"/>	<input type="checkbox"/>
2. The plug is polarized.	<input type="checkbox"/>	<input type="checkbox"/>
3. The equipment input voltage and frequency match those of the building's electrical system.	<input type="checkbox"/>	<input type="checkbox"/>
4. The equipment construction is suitable for the intended operating environment.	<input type="checkbox"/>	<input type="checkbox"/>
5. The equipment is in its original, unmodified and undamaged condition.	<input type="checkbox"/>	<input type="checkbox"/>
6. The equipment has externally accessible supplementary over current protection (e.g. fuses) that are properly sized. (Equipment not having this, needs evaluation to determine if it is safe for use).	<input type="checkbox"/>	<input type="checkbox"/>

NOTE: APPROVED EQUIPMENT SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE INSTRUCTIONS PROVIDED BY THE DESIGNER/BUILDER.

Comments: Include all designer/builder instructions, restrictions on use, drawings or information that is relevant to the safe installation and use of this equipment.

- This equipment is approved for installation or use at Argonne.
- This equipment is rejected for use at Argonne. (See comments above)
- This equipment has been removed from service at Argonne.

Operating Environment:

- Indoor Use Only
- Damp/Wet Locations
- Hazardous/Classified Locations

Expiration Date:

IF THIS EQUIPMENT IS MODIFIED, DAMAGED OR UTILIZED FOR OTHER THAN THE INTENDED USE, THIS APPROVAL IS VOID, PENDING RE-EXAMINATION.

Inspection Date:	Inspector (Name):	Inspector (Signed)
------------------	-------------------	--------------------